

Technical Sheet

Prescriptive Program - HVAC

Effective Date: October 2, 2025

The Delmarva Power Energy Savings for Business Program offers incentives to install energy efficient HVAC, chiller, and variable frequency drive (VFD) equipment.

Click or scroll to view the following sections below:

- <u>Unitary HVAC Equipment</u>
- Geothermal Equipment
- Hotel Room HVAC and Receptacle Controls and Smart Thermostats
- Chill
- o Constant Speed Chillers
- o VFD Chillers
- Variable Frequency Drives and ECMs

To take advantage of these incentives, you must meet the following eligibility requirements:

- 1. Be a Delmarva Power customer and business in the Maryland territory.
- 2. Have an active commercial account.
- 3. Be replacing existing equipment (HVAC or chiller) OR applying for new construction / major renovation incentives

Existing buildings, new construction, and major renovation projects are all eligible for Prescriptive incentives. New construction refers to site preparation for and construction of entirely new structures and/or extensions to existing buildings. Major renovation refers to extensive alteration of an existing building encompassing projects where lighting and HVAC systems are being completely replaced.

Multifamily properties are eligible to apply for these incentives as follows. If tenant units are individually metered, incentives apply only to common areas. Master-metered buildings are offered incentives for tenant units as well as common areas.

All projects require pre-approval. Unitary HVAC projects with an incentive of \$15,000 or less can receive instant pre-approval. New contruction projects are not eligible for instant pre-approval. All applications for pre-approva must be submitted via the <u>Application Centerthe</u>.

You can also contact your installation contractor or equipment vendor to discuss energy efficiency equipment options. If you do not have a contractor or vendor in mind, please visit our website for a list of Service Providers. New construction and/or major renovation projects are not subject to program Service Provider requirements.

All projects MUST receive pre-approval before purchasing equipment or beginning work. Please review the program process and eligibility requirements on the <u>program website</u> as well as the customer-signed <u>Terms and Conditions</u>. Please <u>contact</u> the program office with any questions.

How to Apply:

- 1. Submit the application via the online <u>Application Center</u>. The Application Center Equipment Guide below illustrates how to enter equipment into the online application. <u>Pre-approval is required before purchasing or installing equipment.</u> The following supporting information must be included with the application:
 - ✓ Completed <u>Terms and Conditions (T&Cs)</u> form, signed by the customer
 - i. Manufacturer specification sheets providing SEER/SEER2, EER/EER2, IEER, IPLV, and HSPF2/COP (as applicable) at AHRI conditions
 - ✓ AHRI certificate or screenshot of current listing on AHRI website (note: not all equipment is listed on AHRI website)
- The Program reviews submitted documentation, revises and/or requests additional documentation as necessary. A site inspection may be required as part of the pre-approval process.
- 3. The Program emails the project pre-approval to the customer and Service Provider.
- 4. If the scope of work has changed, then the Program must be notified as soon as possible. If your project increases the incentive amount by more than \$2,500 or 10% of the reserved amount whichever is greater a separate application must be submitted for the variance prior to installation and will need to go through the application pre-approval process.
- 5. Once installation of all proposed equipment is complete and the Delmarva Power customer is satisfied with the equipment and installation, the Pepco customer must sign the program pre-approval letter. The customer-signed pre-approval letter must be uploaded to the online Application Center along with a copy of the invoice. The invoice should include equipment model numbers and quantities. The invoice should match the application information.
- 6. The Program may require a post-installation inspection to verify compliance with program rules, accuracy of project documentation, and equipment operation.
- 7. The Program distributes the incentive check to the payee following final approval processing.



| Unitary HVAC Equipment – Application Center Equipment Guide | | | | | | |
|---|--|--|--|--|--|--|
| Product Type | Category | | | | | |
| | Air Conditioning Only | | | | | |
| Air Conditioners | Residential AC Installed in Commercial Setting (Window Unit) | | | | | |
| | Water-Cooled Air Conditioning | | | | | |
| | Ductless Mini Split Air Conditioner | | | | | |
| | Ground Source Heat Pump | | | | | |
| Geothermal Heat Pumps | Ground Water Source Heat Pump | | | | | |
| | Air Source Heat Pumps | | | | | |
| Lloat Dumos | Air-Cooled Variable Refrigerant Flow Heat Pumps | | | | | |
| Heat Pumps | Ductless Mini Split Heat Pumps | | | | | |
| | Water Source Heat Pump | | | | | |
| Packaged Terminal Fouriement | Packaged Terminal Air Conditioner | | | | | |
| Packaged Terminal Equipment | Packaged Terminal Heat Pump | | | | | |

Please Note:

- 1. The incentive will be based upon actual tons calculated by dividing the rated Btu/hour shown on the specifications by 12,000.
- 2. Measures in the following (**) categories are eligible for an additional \$200/unit incentive when a Dual Enthalpy (DE) Economizer is installed on a new HVAC unit meeting the minimum requirements: Air Conditioning, Air Source Heat Pumps, and Water-Cooled Air Conditioners.

| | | Unitary HV | AC Measures and | Incentives | | | |
|-----------------------------------|--------------------------|-------------------------|-------------------|-------------------|--------------|---------------|--------------------------|
| | Cooling | Capacity | Mini | mum Requiren | | Dual Enthalpy | |
| Unit | Btu/h | Tons | SEER/IEER | EER | HSPF/COP | Incentive | Economizer (Per Unit) |
| | Residen | tail Air Conditioners I | nstalled in Comm | ercial Setting (W | /indow Unit) | | |
| Single Package | N/A | N/A | | ENERGY STAR | | \$25/unit | N/A |
| | | Air Condition Only** | (Units with Elect | ric Heat or No H | eat) | | |
| Split System or Single Package | <65,000, 3 phase | <5.4 | 15.2 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥65,000 and <135,000 | ≥5.4 and <11.25 | 15.5 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥135,000 and <240,000 | ≥11.25 and <20 | 15.0 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥240,000 and <760,000 | ≥20 and <63.3 | 13.8 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥760,000 | ≥63.3 | 12.8 | N/A | N/A | \$300/ton | \$200 |
| | | Air Conditioning I | Jnits Only** (Uni | ts with Gas Heat |) | | |
| Split System or Single Package | <65,000, 3 phase | <5.4 | 15.2 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥65,000 and <135,000 | ≥5.4 and <11.25 | 15.3 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥135,000 and <240,000 | ≥11.25 and <20 | 14.8 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥240,000 and <760,000 | ≥20 and <63.3 | 13.6 | N/A | N/A | \$300/ton | \$200 |
| Split System or Single Package | ≥760,000 | ≥63.3 | 12.6 | N/A | N/A | \$300/ton | \$200 |



| Unitary HVAC Measures and Incentives (Continued) | | | | | | | | |
|--|--------------------------|------------------------|--------------------|-------------------|------------|------------|--------------------------|--|
| | Cooling | Capacity | Mini | mum Requirer | nents | | Dual Enthalpy | |
| Unit | Btu/h | Tons | SEER/IEER | EER | HSPF/COP | Incentive | Economizer (Per Unit) | |
| | Į. | Air Source Heat Pumps | ** (Units with Ele | ctric Heat or No | Heat) | | | |
| Split System | <65,000, 3 phase | <5.4 | 15.2 | N/A | 7.7 | \$500/ton | \$200 | |
| Single Package | <65,000, 3 phase | <5.4 | 15.2 | N/A | 7.0 | \$500/ton | \$200 | |
| Either | ≥65,000 and <135,000 | ≥5.4 and <11.25 | 14.8 | N/A | 3.5 | \$500/ton | \$200 | |
| Either | ≥135,000 and <240,000 | ≥11.25 and <20 | 14.1 | N/A | 3.4 | \$500/ton | \$200 | |
| Either | ≥240,000 | ≥20 | 13.0 | N/A | 3.3 | \$500/ton | \$200 | |
| | | Air Source Hea | t Pumps** (Units | with Gas Heat) | | | | |
| Split System | <65,000 | <5.4 | 15.2 | N/A | 7.7 | \$500/ton | \$200 | |
| Single Package | <65,000 | <5.4 | 15.2 | N/A | 7.0 | \$500/ton | \$200 | |
| Either | ≥65,000 and <135,000 | ≥5.4 and <11.25 | 14.6 | N/A | 3.5 | \$500/ton | \$200 | |
| Either | ≥135,000 and <240,000 | ≥11.25 and <20 | 13.9 | N/A | 3.4 | \$500/ton | \$200 | |
| Either | ≥240,000 | ≥20 | 12.8 | N/A | 3.3 | \$500/ton | \$200 | |
| | Wate | er-Cooled Air Conditio | ners** (Units with | n Electric Heat o | r No Heat) | | | |
| Single Package | <65,000 | <5.4 | 13.1 | 11.9 | N/A | \$300/ton | \$200 | |
| Single Package | ≥65,000 and <135,000 | ≥5.4 and <11.25 | 14.6 | 11.9 | N/A | \$300/ton | \$200 | |
| Single Package | ≥135,000 and <240,000 | ≥11.25 and <20 | 14.6 | 12.3 | N/A | \$300/ton | \$200 | |
| Single Package | ≥240,000 and <760,000 | ≥20 and <63.3 | 13.8 | 12.2 | N/A | \$300/ton | \$200 | |
| Single Package | ≥760,000 | ≥63.3 | 13.8 | 12.0 | N/A | \$300/ton | \$200 | |
| | | Packaged T | erminal Air Condi | tioners*** | | | | |
| Single Package | <8,000 | N/A | N/A | 12.9 | N/A | \$75/unit | N/A | |
| Single Package | ≥8,000 and <11,000 | N/A | N/A | 12.2 | N/A | \$95/unit | N/A | |
| Single Package | ≥11,000 and <14,000 | N/A | N/A | 11.4 | N/A | \$115/unit | N/A | |
| Single Package | ≥14,000 | N/A | N/A | 10.4 | N/A | \$135/Unit | N/A | |

^{*}Note that the incentive will be based upon actual tons calculated by dividing the rated Btu/hour shown on the specifications by 12,000.

**Measures in the following categories are eligible for an additional \$200/unit incentive when a Dual Enthalpy (DE) Economizer is installed on a new HVAC unit meeting the minimum requirements: Air Conditioning, Air Source Heat Pumps, and Water Cooled Air Conditioners.

***For replacement of standard size systems



| | Unitary HVAC Measures and Incentives (Continued) | | | | | | | |
|-----------------|--|----------|------------------|--------------|----------|------------|--------------------------|--|
| | Cooling | Capacity | Mini | mum Requirem | nents | Incentive | Dual Enthalpy | |
| Unit | Btu/h | Tons | SEER/IEER | EER | HSPF/COP | | Economizer (Per Unit) | |
| | | Packag | ed Terminal Heat | Pumps | | | | |
| Single Package | <8,000 | N/A | N/A | 12.9 | 3.5 | \$75/unit | N/A | |
| Single Package | ≥8,000 and <11,000 | N/A | N/A | 12.2 | 3.4 | \$95/unit | N/A | |
| Single Package | ≥11,000 and <14,000 | N/A | N/A | 11.4 | 3.2 | \$115/unit | N/A | |
| Single Package | ≥14,000 | N/A | N/A | 10.4 | 3.1 | \$135/unit | N/A | |
| | Ductless, Mini-Split Air Conditioners and Heat Pumps | | | | | | | |
| AC Split System | <65,000 | <5.4 | 15.2 | N/A | N/A | \$225/ton | N/A | |
| HP Split System | <65,000 | <5.4 | 15.2 | N/A | 7.4 | \$500/ton | N/A | |

| | Geothermal Measuers and Incentives | | | | | | | | |
|------------------------|---|---------------|-----------|-----------|------|---------|-----------|--|--|
| Qualifying equipment m | Qualifying equipment must meet or exceed the minimum EER/COP outlined in the table below. | | | | | | | | |
| | Program Minimum and Incentives | | | | | | | | |
| Unit | Capacity (Btu/h) | | Tier I | | | Tier II | | | |
| | | EER | COP | Incentive | EER | COP | Incentive | | |
| | Water Source Heat Pumps | | | | | | | | |
| Water to Air | <17,000 | 13.2 | 4.7 | \$300/ton | N/A | N/A | N/A | | |
| Water to Air | ≥17,000 and <135,000 | 14 | 4.7 | \$300/ton | N/A | N/A | N/A | | |
| Water to Water | ≥17,000 and <135,000 | 11.6 | 4 | \$300/ton | N/A | N/A | N/A | | |
| | Gro | und Source He | eat Pumps | | | | | | |
| Brine to Air | <135,000 | 15.5 | 3.4 | \$500/ton | 16.2 | 3.5 | \$700/ton | | |
| Brine to Water | <135,000 | 13.3 | 2.6 | \$500/ton | 13.9 | 2.8 | \$700/ton | | |
| | Ground Water Source Heat Pumps | | | | | | | | |
| Water to Air | <135,000 | 19.8 | 3.9 | \$500/ton | 20.7 | 4.1 | \$700/ton | | |
| Water to Water | <135,000 | 17.9 | 3.3 | \$500/ton | 18.7 | 3.4 | \$700/ton | | |

Variable Refrigerant Flow Measures and Incentives

Eligible variable refrigerant flow (VRF) heat pumps are systems that do not incorporate heat recovery capability. VRF heat pump systems with heat recovery are eligible for Custom path incentives.

| Cooling Capacity Btu/h | Cina Catagogy (tops) | | Incentive | | | |
|-------------------------|----------------------|-----------|-----------|--------------|--------------|-----------|
| | Size Category (tons) | SEER/IEER | EER | COP at 47° F | COP at 17° F | incentive |
| < 65,000 | <5.4 | 15.2 | N/A | 8.5 (HSPF) | 8.5 (HSPF) | \$500/ton |
| ≥ 65,000 and < 135,000 | ≥ 5.4 and < 11.25 | 14.2 | N/A | 3.4 | 2.4 | \$500/ton |
| ≥ 135,000 and < 240,000 | ≥ 11.25 | 13.7 | N/A | 3.2 | 2.1 | \$500/ton |
| ≥ 240,000 | ≥ 20 | 12.5 | N/A | 3.2 | 2.1 | \$500/ton |

VFD and EC Motor Instructons

- 1. If submitting an application for a Standard measure, enter data requested on the online VFD or EC motor application. Annual savings will be automatically calculated.
- 2. If submitting an application for any Custom measure, enter data requested on the online Custom application. For these measures, the user is required to calculate annual savings and enter those data into the online application. All calculations and methodology supporting the annual kWh and kW savings must be provided.



| VFD and EC Motor Application Center Equipment Guide | | | | | | | |
|---|---------------|-------------------------------------|--|--|--|--|--|
| Product Type | Category | Equipment Attribute | | | | | |
| | | HVAC Supply Fans | | | | | |
| V : II 5 | VED E | HVAC Return Fans | | | | | |
| Variable Frequency Drives | VFD Fan | Cooling Tower Fans | | | | | |
| | | HVAC Make Up Air Fans | | | | | |
| | | HVAC Exhaust Fans | | | | | |
| | | Chilled Water Supply/Return Pumps | | | | | |
| W : 11 5 | | Condenser Water Supply/Return Pumps | | | | | |
| Variable Frequency Drives | VFD Pump | Hot Water Supply/Return Pumps | | | | | |
| | | Hot Water Circulation Pumps | | | | | |
| | | Heat Water Pumps | | | | | |
| Electronically Commutated Motors | EC Motor Fan | HVAC Circulation Fans | | | | | |
| Floatropically Commutated Motors | EC Motor Dumo | Heating Circulation Pumps | | | | | |
| Electronically Commutated Motors | EC Motor Pump | DHW Recirculation Pumps | | | | | |

VFD and EC Motor Measures and Incentives*

Incentives are awarded based upon the VFD or EC motor horsepower (HP) rating and type of equipment controlled. If the equipment controlled is identified as Standard, then the incentive is calculated based upon HP (see incentive table immediately following). If the equipment controlled is identified as Custom, then the incentive must be applied for through the Custom program. The custom incentive is calculated at a rate of \$0.28/kWh for one year of projected kWh savings, up to 50% of installed cost. Custom projects must pass the Societal Cost test.

*To qualify for an incentive, the motor(s) being controlled must operate a minimum of 2,000 hours per year. VFD measures are only eligible in retrofit applications. Replacement of failed VFDs and EC motors, or installation in new construction or major renovation projects are not eligible.

| | VFD Incentives for both Standard and Custom Measures | | | | | | | |
|-----------------------|--|--|-------------|--|--|--|--|--|
| VFD Horsepower Rating | Per Unit Incentive ¹ | Per Unit Incentive ¹ VFD Horsepower Rating Per Unit | | | | | | |
| 2 | \$500 | 30 | \$1,800 | | | | | |
| 3 | \$600 | 40 | \$2,000 | | | | | |
| 4 | \$700 | 50 | \$2,500 | | | | | |
| 5 | \$800 | 60 | \$3,000 | | | | | |
| 7.5 | \$900 | 75 | \$3,750 | | | | | |
| 10 | \$1,100 | 100 | \$5,000 | | | | | |
| 15 | \$1,350 | 101 to ≤200 | \$50 per HP | | | | | |
| 20 | \$1,500 | >200 | \$50 per HP | | | | | |
| 25 | \$1,600 | ¹ Custom measures may be adjusted. See <u>Terms and Conditions</u> for details. | | | | | | |

| EC Motor Incentives for both Standard and Custom Measures | | | | | | | |
|---|--|--|--|--|--|--|--|
| EC Motor Horsepower Rating | Per Unit Incentive ¹ | | | | | | |
| <1 | \$100 | | | | | | |
| ≥1 to <2 | \$125 | | | | | | |
| ≥2 to <3 | \$150 | | | | | | |
| ≥3 to ≤5 | \$200 | | | | | | |
| >5 to ≤10 | \$400 | | | | | | |
| >10 | ¹ Custom measures may be adjusted. See <u>Terms and Conditions</u> for details. | | | | | | |



Prescriptive Chiller Eligibility and Incentive Calculations

Eligible systems are air- and water-cooled water chilling packages, 1,000 tons and less, used in single-chiller HVAC applications. Water-chilling equipment must meet the current AHRI standard 550/590, be UL-listed, and comply with EPA Section 608. Chillers installed in multiple chiller systems and chillers serving a non-HVAC load greater than 25% of chiller capacity are not eligible under this application form, but customers using these systems may apply using the Pepco Custom application form.

*Note: the Performance Incentive is applied for each 0.1 EER point above or for each 0.01 kW/ton below minimum efficiency Full Load or Integrated Part Load Value (IPLV). Total incentive is capped at \$200/ton for all air-cooled chillers and water-cooled centrifugal chillers and \$175/ton for water-cooled positive displacement chillers.

| | Constant Speed Chiller Measures and Incentives (Path A) | | | | | | | | |
|--------------------------|---|------------------|-------------|-----------|-------------|---------------------------------------|-------------------------------------|--|--|
| Equipment Type | Unit Size (ARI Net | Minimum | Efficiency | Incentive | | Application Center Equipment Guide | | | |
| | Tons) | Full Load | IPLV | Base | Performance | Product Type | Category | | |
| Air-Cooled Chiller | <150 | 10.1 EER | 14 EER | \$24/ton | \$8/ton | LIVAC | Air-Cooled Chillers | | |
| with Condenser | ≥150 | 10.1 EER | 14.2 EER | \$24/ton | \$8/ton | HVAC | All-Cooled Chillers | | |
| | <75 | 0.75 kW/ton | 0.54 kW/ton | \$15/ton | \$6/ton | ΗΛΑ | | | |
| Water-Cooled | ≥75 and <150 | 0.72 kW/ton | 0.54 kW/ton | \$15/ton | \$6/ton | | Electric, Water- Cooled Chillers | | |
| Positive Displacement | ≥150 and <300 | 0.66 kW/ton | 0.52 kW/ton | \$15/ton | \$6/ton | | | | |
| Chillers | ≥300 and <600 | 0.61 kW/ton | 0.50 kW/ton | \$15/ton | \$6/ton | | Cooled Chillers | | |
| | ≥600 and ≤1000 | 0.56 kW/ton | 0.48 kW/ton | \$15/ton | \$6/ton | | | | |
| | <150 | 0.61 kW/ton | 0.53 kW/ton | \$20/ton | \$8/ton | | | | |
| Water-Cooled, | <150 and <300 | 0.61 kW/ton | 0.53 kW/ton | \$20/ton | \$8/ton | | FI | | |
| Centrifugal Chillers | ≥300 and <400 | 0.56 kW / ton | 0.50 kW/ton | \$20/ton | \$8/ton | HVAC | Electric, Water- Cooled Chillers | | |
| | ≥400 and ≤1000 | 0.56 kW/ton | 0.48 kW/ton | \$20/ton | \$8/ton | | | | |

| VFD Speed Chiller Measures and Incentives (Path B) | | | | | | | | |
|--|--------------------|--------------------|-------------|-----------|-------------|---------------------------------------|-------------------------------------|--|
| Equipment Type | Unit Size (ARI Net | Minimum Efficiency | | Incentive | | Application Center Equipment Guide | | |
| | Tons) | Full Load | IPLV | Base | Performance | Product Type | Category | |
| Air-Cooled Chiller | <150 | 9.7 EER | 16 EER | \$24/ton | \$8/ton | HVAC | Air-Cooled Chillers | |
| with Condenser | ≥150 | 9.7 EER | 16.3 EER | \$24/ton | \$8/ton | HVAC | All-Cooled Chillers | |
| | <75 | 0.78 kW/ton | 0.48 kW/ton | \$20/ton | \$10/ton | | | |
| | ≥75 and <150 | 0.75 kW/ton | 0.47 kW/ton | \$20/ton | \$10/ton | | | |
| Water-Cooled Positive | ≥150 and <300 | 0.68 kW/ton | 0.42 kW/ton | \$20/ton | \$10/ton | HVAC | Electric, Water- Cooled Chillers | |
| Displacement Chillers | ≥300 and <600 | 0.625 kW/ton | 0.38 kW/ton | \$20/ton | \$10/ton | | | |
| | ≥600 and ≤1000 | 0.585 kW/ton | 0.36 kW/ton | \$20/ton | \$10/ton | | | |
| | <150 | 0.695 kW/ton | 0.42 kW/ton | \$25/ton | \$10/ton | | | |
| Water-Cooled, | ≥150 and <300 | 0.635 kW/ton | 0.38 kW/ton | \$25/ton | \$10/ton | LIVAC | Electric, Water- | |
| Centrifugal Chillers | ≥300 and <400 | 0.595 kW/ton | 0.37 kW/ton | \$25/ton | \$10/ton | HVAC | Cooled Chillers | |
| | ≥400 and ≤1000 | 0.585 kW/ton | 0.36 kW/ton | \$25/ton | \$10/ton | | | |



Custom Chiller Measure Definitions

Measures are designated as Custom if:

- 1. The project has more than one chiller on the same chilled water line, or
- 2. The chiller has greater than 1,000 tons cooling capacity.

Chillers installed in multiple chiller systems and chillers serving a non-HVAC load greater than 25% of chiller capacity are not eligible under the prescriptive application form, but customers using these systems may apply using the Custom application form.

Custom Chiller Measure Additional Information

- 1. If submitting an application for any Custom measure, enter data requested on the online Custom application.
- 2. If submitting an application for any Custom measure, please contact the program office to request a scoping call. This call will establish the baseline from which project savings will be claimed, and establish what, if any, trend data will need to be provided to verify savings. Please note an energy model or other savings calculation will be required for preapproval. Refer to the <u>Custom technical sheet</u> for more information.
- 3. The user is also required to supply the average electricity price. This is the price that the facility paid over the last 12 months, inclusive of the distribution costs, fuel cost, demand charge, and all taxes and applicable rider charges. This is calculated as the sum of all electricity charges over the past 12 months divided by the kWh used over the same period.

Refer to the **Terms and Conditions** for additional information.

Hotel Room HVAC and Receptacle Controls Incentives

Smart Thermostats: Only for central AC, HP, furnace or RTUs with cooling capacities up to 300 kBtuh.

Must be installed in normally conditioned spaces - not partially conditioned or with frequently opened doors.

Eligible only for thermostats that certified ENERGY STAR® or have all the following capabilities:

- 1. Automatic scheduling
- 2. Occupancy sensing ("on" as default)
- 3. Must be capable of optimizing heat pump energy use, minimize supplemental heat
- 4. Must be able to control via smart phone or online
- 5. Must be able to view temp, adjust temp, and switch between "heating," "cooling" and "off," settings
- 6. Static temp accuracy of < +/- 2 deg F
- 7. Network standby average power consumption of < 3W, including all equipment needed to maintain connectivity

Hotel Room HVAC and Receptacle Controls: Facility must be a lodging business. Incentives are for occupancy-based guest room energy management controls. Occupancy control may be room-key activated or sensed due to motion and/or sound and must control the HVAC system serving the room. Front desk control systems and new construction are not eligible.

| Equipment Type | Per Unit Incentive | Application Center Equipment Guide | | | |
|--------------------------|--------------------|------------------------------------|----------|--|--|
| | | Product Type | Category | | |
| Smart Thermostats | \$100/thermostat | HVAC | Controls | | |
| Hotel Room HVAC Controls | \$140/room | HVAC | Controls | | |
| Receptacle Controls | \$10/control | HVAC | Controls | | |

Delmarva Power Energy Savings for Business Program

Contact: 1-866-353-5799 | delmarvabusiness@icf.com

